

---

## Declaration of conformity in accordance with EU Directive 2014/68/EU (Pressure Equipment Directive)

Talleres mecánicos HERBE,S.L.  
Mallutz, Bloque 3, Edif.2, Locales 20-21  
20240 Ordizia - Spain

The valves type: **HC, PAL, PAL-LUG-, HMC, HCFR, HPDG y TP**

Applied conformity assessment procedures:  
**Module A**

Fulfill the requirements for Category I, group 1 and group 2 according to the article 13 of the DIRECTIVE 2014/68/EU.

	<b>Flanges</b>	<b>Nominal Diameter</b>	<b>Max. Pressure Service</b>
Group 1	PN10	50 to 100	10 bar
Group 2	PN10	125 to 250	10 bar
		300	6 bar
		350 to 400	5 bar
		450 to 500	4 bar
		600	3 bar

---

Applied harmonized norms and standards:  
*EN 1092, ASME B16.5, EN 12266*

**HERBE, S.L.**, is not responsible for any modifications that could affect to the approved design and/or delivered product.  
Is user responsibility to verify the compatibility of the fluid with the valve construction materials according to the service conditions.

Ordizia, February 18, 2020

Ivan Pascual  
General Manager

