
Declaration of conformity in accordance with EU Directive 2014/68/EU (Pressure Equipment Directive)

Talleres mecánicos HERBE,S.L.
Mallutz, Bloque 3, Edif.2, Locales 20-21
20240 Ordizia - Spain

The valves type: **RD**
Nominal Diameter: **DN32 - DN250** Nominal Pressure: **PN6 to PN40**
Nominal Diameter: **DN32 - DN250** Nominal Pressure: **Class 125 - Class 150**

Material: **ST 52.0** s/DIN 1629, **CF8M** s/ASTM A351
F316L s/ASTM A182, **CC491K** s/UNE-EN 1982

Category I, II, III, fluid group 1 and group 2 according to the article 13 of the
DIRECTIVE 2014/68/EU

Applied conformity assessment procedures:

Module B N°0038/PED/MAD/1347
Module C2 N°0038/PED/MAD/5289 SPA

Surveillance under the responsibility of:

LLOYD ´S REGISTER VERIFICATION LIMITED
71 Fenchurch Street
LONDON EC3M 4BS -United Kingdom

 0038

Applied harmonized norms and standards:

EN 12516, EN 558, EN 1092, ASME B16.5, EN 12266

HERBE, S.L., will not be responsible for any modifications not transmitted to the commercial department of Herbe that may affect to the approved design.

Warning, Is customer responsibility, to verify the compatibility of the fluid in service conditions with the valve construction material.

Ordizia, February 18, 2020

Ivan Pascual
General Manager

