
Declaration of conformity in accordance with EU Directive 2014/68/EU (Pressure Equipment Directive)

HERBE VALVES, S.L.
Mallutz, Bloque 3, Edif.2, Locales 20-21
20240 Ordizia - Spain

The valves type: **DC**
Nominal Diameter: **DN50 - DN800** Nominal Pressure: **PN6 to PN40**
Nominal Diameter: **DN50 - DN600** Nominal Pressure: **Class 125 - Class 150**

Material: **ST 52.0 s/DIN 1629, CF8M s/ ASTM A351/A351**

Category I, II, III, fluid group 1 and group 2 according to the article 13 of the
DIRECTIVE 2014/68/EU

Applied conformity assessment procedures:

Module B LRE 0094/PED/MAD/2773
Module C2 LRE 0094/PED/MAD/10125 SPA

Surveillance under the responsibility of:

LLOYD'S REGISTER ESPAÑA, S.A.
C/ PRINCESA 29, 1º
28008 - Madrid

 LRE 0094

Applied harmonized norms and standards:
EN 12516, EN 558, EN 1092, ASME B16.5, EN 12266

HERBE VALVES, S.L., will not be responsible for any modifications not transmitted to
the commercial department of Herbe that may affect to the approved design.

Warning, Is customer responsibility, to verify the compatibility of the fluid in service
conditions with the valve construction material.

Ordizia, March, 2021


Ivan Pascual
General Manager